



DELHI PUBLIC SCHOOL NASHIK
UNDER THE AEGIS OF DELHI PUBLIC SCHOOL SOCIETY, NEW DELHI
info@dpsnashik.in www.dpsnashik.in

Campus
Village Manori,
Behind Maharashtra University of Health Science,
Dindori Road, Nashik - 422 004
Maharashtra, Ph. : + 91 8888897210, 8888119210

Admin. Office
2nd Floor, Suyojit Heights,
Opp. Rajiv Gandhi Bhavan,
Sharanpur Road, Nashik - 422 002
Ph. : + 91 253 6640550-51 / 2574155

APPENDIX - VIII

PROFORMA

REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

No. 603/2024

Date: 13/08/2024

It is certified that an inspection team headed by

MEDICAL OFFICER

P.H.C Talgaon (Dindori) Tal. Dindori

from PRIMARY HEALTH CENTRE Talgaon(d.) inspected the Delhi Public School Nashik, Village Manori, Behind Maharashtra University of Health Science, Off Vani Dindori Highway, Nashik 422 004 on 27/07/2024 and found that the Delhi Public School Nashik has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 6 Months

Signature with Seal:

Name:

Designation:

[Signature]
Medical Officer
PHC Talgaon (Dindori)
Tal.Dindori, Dist Nashik

To

Delhi Public School Nashik,

Village Manori, Behind Maharashtra University of Health Science,

Off Vani Dindori Highway, Nashik-422004



**Maharashtra Government
DISTRICT PUBLIC HEALTH LABORATORY, NASHIK**

Office Phone No.:- 0253 – 2570613

Email Id:- dphlnasik@gmail.com

Office: - Junior Scientific Officer District Public Health,
Laboratory, Civil Hospital Campus, Trimbak Road, Nashik -
422 001.

NO. DPHL/NSK/WC/ W-154/ 3600 /2024

Date:- 26 / 7 /2024

Health Services

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection- ----- Date of receipt -18/07/2024 Date of Examination-18/07/2024 & onwards

Letter No.NIL

Analytical results in mg/litre (except pH& turbidity)

Sr. No.	Name of Test	Results	BIS Specification 10500:2012 Normal values	
			Desirable limits	Permissible limits
	Source	RO Plant	-----	-----
01	Physical appearance	Clear, Colorless	-----	-----
02	Odor	Odorless	Agreeable	Agreeable
03	p ^H	7.46	6.5 to 8.5	No relaxation
04	Turbidity (NTU)	0.10	1.0	5.0
05	Chlorides	81.63	250	1000
06	Total Hardness	96	200	600
07	Total alkalinity	57.28	200	600
08	Total dissolved solids	228	500	2000
09	Fluoride	0.02	1.0	1.5
10	Iron	0.06	0.3	No relaxation
11	Nitrates	6.00	45	No relaxation
12	Permanent hardness	38.72	-----	-----

Remark:- The above sample no. 01 is chemically fit for drinking purpose on the basis of analyzed parameters only. However, this water source can be used for drinking purpose only after proper treatment, disinfection and ascertaining their bacteriological quality frequently or regularly.

Forwarded with compliments to:
Principal, Delhi Public School,
Behind MUHS, Dindori Highway,
Nashik.

Junior Scientific Officer
District Public Health Laboratory,
Nashik.

R.No.-5145796, Rs.600/-, Dt-18/07/2024



JUNIOR SCIENTIFIC OFFICER,

DISTRICT PUBLIC HEALTH LABORATORY, NASHIK.

Civil Hospital Campus, Trimbak road, Nashik - 422001

E-mail: dphlnasik@gmail.com

Phone:- 0253-2570613

• REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE •

Sender's Name :- ✓ Principal, Delhi Public School, Nashik,

Address :- Village Manori, Behind MUHS, Dindori Road, Nashik, Dist. Nashik.

Sender's Letter No. & Date :- 18/07/2024 Laboratory Reference No. :- 1072

Date of Sample Collection :- 18/07/2024

Date of Arrival at Laboratory :- 18/07/2024

Date of Commencing Examination:- 18/07/2024

Sr. No.	Particulars of Water Samples	Results of Analysis			Remark
		Most Probable Number of bacteria Per 100 ml.			
		Coliforms	Thermotolerant coliforms	<i>E.coli</i>	
1	R O Filter Plant Water Sample	0	0	0	<u>Potable</u>

Receipt No :- 5145796

Fee Rs. :- 1880/-

Date:- 18/07/2024

Note :- Result/ Report mentioned above is/are of sample/s submitted to this laboratory only.

Outward No:-

3550/24

Date:-

24.7.2024


Junior Scientific Officer
 District Public Health Laboratory,
 Nashik.